



**CX-WC17 EQUIPMENT PACKAGE:**

- 1 CX-33 Multi-Function Relay
- 2 CM-7536/4-LED - 36" STAINLESS STEEL COLUMN SWITCH WITH 'WHEELCHAIR' SYMBOL AND 'PUSH TO OPEN' GRAPHICS AND MOUNTED LED
- 3 CM-7536/4 - 36" STAINLESS STEEL COLUMN SWITCH WITH 'WHEELCHAIR' SYMBOL AND 'PUSH TO OPEN' GRAPHICS AND MOUNTED LED
- 4 CM-7536/8B-LED - 36" STAINLESS STEEL COLUMN SWITCH WITH 'LOCK' SYMBOL AND 'PUSH TO LOCK' GRAPHICS AND MOUNTED LED
- 5 CX-MDA - MAGNETIC DOOR CONTACT

**CX-WEC10K2 EQUIPMENT PACKAGE:**

- 6 CM-AF540SO - 'PRESS FOR EMERGENCY ASSISTANCE' SWITCH & 'ASSISTANCE REQUESTED' LED ANNUNCIATOR WITH SOUNDER
- 7 CM-AF141SO - 'ASSISTANCE REQUIRED' SINGLE GANG LED DOME LIGHT WITH SOUNDER
- 8 CM-SE21A - EMERGENCY ASSISTANCE SIGN

**ADDITIONAL PARTS REQUIRED BUT NOT INCLUDED WITH THE CX-WC17 & CX-WEC10K2:**

- 9 CX-ED2079 - GRADE 2 UNIVERSAL ELECTRIC STRIKE
- 10 DOOR OPERATOR - SUPPLIED BY OTHERS
- 11 CX-PS13 - 12/24 VDC LINEAR POWER SUPPLY
- 12 CX-TRX-4024 - 40VA, 24 VAC TRANSFORMER

**SYSTEM OPERATION**

**CX-WC17 OPERATION:**

- A. THE DOOR IS NORMALLY CLOSED AND UNLOCKED.
- B. PRESSING THE EXTERIOR COLUMN 'PUSH TO OPEN' SWITCH OPENS THE DOOR.
- C. ONCE INSIDE AND THE DOOR IS CLOSED, PRESSING THE 'PUSH TO LOCK' COLUMN SWITCH LOCKS THE DOOR, DISABLING THE EXTERIOR 'PUSH TO OPEN' COLUMN AND ILLUMINATES THE EXTERIOR AND INTERIOR LED ANNUNCIATOR FROM GREEN TO RED
- D. PRESSING THE INTERIOR 'PUSH TO OPEN' SWITCH UNLOCKS THE DOOR, DEACTIVATES THE ILLUMINATED LED ANNUNCIATOR AND RESETS THE SYSTEM
- E. IF THE DOOR IS OPENED MANUALLY TO EXIT THE RESTROOM, THE OVERHEAD MAGNETIC CONTACT SWITCH RESETS THE SYSTEM.

**CX-WEC10K2 OPERATION:**

- A. THE 'PRESS FOR EMERGENCY ASSISTANCE' MUSHROOM PUSH BUTTON IS ACTIVATED BY THE OCCUPANT.
- B. THIS ENERGIZES THE LED ANNUNCIATOR AND SOUNDER WITHIN THE WASHROOM, AND THE DOME LIGHT WITH SOUNDER OUTSIDE THE WASHROOM.
- C. BOTH ANNUNCIATORS WILL BE ENERGIZED UNTIL THE LATCHING MUSHROOM PUSH BUTTON SWITCH IS PULLED OUT.

WIRE SPECIFICATION	
A	2 x 18 AWG
B	2 x 22 AWG
C	3 x 22 AWG

**CAMDEN DOOR CONTROLS**  
 5502 Timberlea Blvd.  
 Mississauga, ON Canada L4W 2T7  
 Tel: (905) 366-3377  
 www.camdencontrols.com

DRAWN	NAME	DATE	TITLE:
CHECKED	A.OLISA	OCT.25	WASHROOM BARRIER FREE DOOR CONTROL NORMALLY UNSECURED & EMERGENCY CALL SYSTEMS (CX-WC17 & CX-WEC10K2)
ENG APPR.			
MFG APPR.			
QA			
COMMENTS:			

SIZE	DWG. NO.	REV
B	CX-WC17 & CX-WEC10K2_RISER.DWG	
SCALE: N/A	SHEET 1 OF 1	