

The Invision TAC™ system supports up to 4 panel mounted card readers and 12 remote CV-TAC4WC wiegand controllers, used for connection of remote prox. readers or keypads. In addition up to 4 CV-TAC4WC wiegand controllers may be designated for elevator cab control.

Each reader or CV-TAC4WC is required to have a specific DIP switch setting, dependent upon the panel address used to program device.

CV-TAC4WC dip switch addresses are as follows:

ADDRESS	DIP SWITCH OFF
2	7 off
3	7 & 8 off
4	6 off
5	6 & 8 off
6	6 & 7 off
7	6, 7, & 8 off
8	5 off
9	5 & 8 off
10	5 & 7 off
11	5, 7, & 8 off
12	5 & 6 off
13	5, 6, & 8 off
14	5, 6, & 7 off
15	5, 6, 7, & 8 off
16	4 off
40	3 & 5 off
41	3, 5, & 8 off
42	3, 5, & 7 off
43	3, 5, 7, & 8 off

For additional information, please refer to the system manual, contained on the software CD supplied with the Invision TAC™ panel.

For technical support, please contact at (877) 226-3369 or by email at jross@camdencontrols.com

